

Appendix B

Certified Validation Report Template, Part A: Provided by Validator

Audit Information:

Water Supplier Name: City of Oxnard PWS ID: 5610007
System Type: Potable Retailer Audit Period: 2019 calendar year
Utility Representation: Omar Castro, Water Division Manager
Validation Date: 8-12-2020 Sufficient Supporting Documents Provided: Yes

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 54 Data Validity Band (Level): Level 3
ILL: 1.22 Real Loss: 17.42 gallons/connection/day Apparent Loss: 11.8 gallons/connection/day
Non-revenue water as percent of cost of operating system: 5.8%

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

If not, rejected recommendations are included here. NA

Validator Information:

Water Audit Validator : Brad Milner, Milner-Villa Consulting LLC

Qualifications: Water Audit Validator Certificate issued by the CA-NV Section of the AWWA

Validator Provided

Certified Validation Report Template, Part B: Provided by Utility

Water Supplier Name: City of Oxnard **Water Supplier ID Number:** 5610007 **Water Audit Period:** 2019 calendar year

Water Audit & Water Loss Improvement Steps:

Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

- City staff conduct fire hydrant maintenance including pressure readings.
- City installed a distribution system pressure sensor in 2020 (credit to 2020 audit).
- City will consider starting customer meter replacement program in near future (potentially 2021).
- City will consider conducting regular testing/calibration of production meters.
- City will consider a data handling audit.

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Omar Castro

Water Division Manager

Executive Name (Print):

Executive Position:

Signature:

Date:

8-15-2019

Utility Provided